

TCR Magnetic Field Analysis

Francisco Velez, PhD

Dominion Profile

Primary Operating Segments Overview

Dominion Virginia Power



Electric Transmission

- ❖ **6,400 miles** of transmission lines
- ❖ Favorable regulatory environment

Electric Distribution

- ❖ **57,000 miles** of distribution lines
- ❖ **2.5 million** franchise retail customer accounts in VA and NC

Dominion Energy



Gas Transmission

- ❖ Together with Gas Distribution, operates one of the largest natural gas storage systems in the U.S.
- ❖ **10,900 miles** of pipeline in six states
- ❖ Well positioned in Marcellus and Utica Shale regions

Gas Distribution

- ❖ **21,900 miles** of distribution pipeline and **1.3 million** franchise retail natural gas customer accounts in OH & WV

Blue Racer Joint Venture

- ❖ Utica Shale midstream services

Dominion Generation



Utility Generation

- ❖ **19,600 MW** of capacity
- ❖ Balanced, diverse fuel mix
- ❖ Favorable regulatory environment

Merchant Generation

- ❖ **4,000 MW** of capacity, including nuclear, gas and renewable power
- ❖ Active hedging program for energy revenue/margins

Dominion Retail


- ❖ Retail Gas & Products/Services
- ❖ **1.5 million** non-regulated customer accounts in **10** states*

Dominion Profile

Power and Natural Gas Infrastructure

Leading provider of energy and energy services in the Midwest, Northeast and Mid-Atlantic regions of the U.S.

- 23,600 MW of electric generation
- 6,400 miles of electric transmission
- 10,900 miles of natural gas transmission, gathering and storage pipeline
- 947 billion cubic feet of natural gas storage operated
- Cove Point LNG Facility
- 2.5 million electric customers in VA and NC
- 1.3 million natural gas customers in OH & WV
- 1.5 million non-regulated retail customers in 10 states* (not shown)



Engineering Support Group

- **System Studies for Dominion**






SVC

TCR Magnetic Field Study

SVC Requirement


- **2 SVC installed in 2014**
- **Voltage recovery for transmission system disturbances**
- **Fast reactive power compensation for system undervoltages produced by system faults**
- **PJM Voltage Recovery Criteria**
 - **0.7 p.u. @ 20 cycles**
 - **0.9 p.u. @ 1 second**

Dominion SVC (-150/+250 MVAR)



TCR Function

- TCRs provide a variable inductance
- The MVAR output depends on the firing angle (α)
- Works with fixed cap banks and TSCs to provide exact amount to reactive power



SVC TCR's




SVC Construction


- **Currents were measured in the ground grid of the substation during installation of the SVC**
- **Initial assessment indicated that the currents were present during the TCR operation**
- **A formal investigation was initiated to find the source of the circulating currents**

Magnetic Fields

- **Magnetic field is produced when a conductor carries current (2667 amps).**
- **A TCR is a winding capable of producing magnetic fields ($N \cdot i$).**
- **TCR model in Maxwell 3D**



Ground Grid Diagram




Simulation Approach



- **ANSYS Maxwell 3D simulation software**
- **Eddy current solver was chosen due to its capability to calculate AC magnetic fields**
- **Ground Grid replaced by a copper ring**
- **The TCR's were simulated at full power output of 200 MVAR (2667 Amperes)**

TCR Simulation

- **Copper ring of ½ inch diameter simulation a 4/0 copper ground wire**
- **Magnetic fields and induced currents were calculated at ground level and 8 feet above ground**




Reactor Arrangement




Flat Design	Delta Design
 The Flat Design diagram shows three identical black circles arranged in a perfectly horizontal line, representing a flat reactor bed.	 The Delta Design diagram shows three identical black circles arranged in a triangular pattern, with one circle at the top and two circles below it, representing a delta reactor bed.

Magnetic Field Study

- **Model was built by Abhijeet Gujrati, a University of Pittsburgh Graduate Student during a summer internship**




Magnetic Field Plots




Currents in Copper Loop

- Flat Design
50 Amps



- Delta Design
13 Amps



Simulation Results

#	Model	Current in the 4/0 wire
1	Flat design 51 feet radius 8 feet above ground	76 Amperes
2	Flat design 51 feet radius 0 feet above ground	50 Amperes
3	Flat design 60 feet radius 0 feet above ground	35 Amperes
4	Delta design 51 feet radius 8 feet above ground	20 Amperes
5	Delta design 51 feet radius 0 feet above ground	13 Amperes
6	Delta design 60 feet radius 0 feet above ground	8 Amperes

Conclusion



- **Delta design currents are $\sim 1/4$ of the flat design. (Inductance needs to be verified)**
- **9 feet of extra clearance reduced currents to $\sim 65\%$ in simulations**
- **Single Point Grounding**
- **Avoid conductive loops near the TCR's**
- **Add magnetic clearance distance between reactors and closed conductive loops**

TCR Magnetic Field Analysis


Questions?

Comparison to Field Measurements

- **G1 Measured: 920 milli Gauss (Z component)**
- **G1 Simulation: 800 milli Gauss (Z component)**



Future Work: Inductance Change



$$\text{Inductance} = \frac{N^2}{\text{length}/\mu * \text{Area}}$$